



CERTIFICATE OF CONFORMANCE

PPF PARTNERS FIRESTOP BRAND PRODUCTS

Firestop 3300PS	(Putty Stick)	Firestop EBI60	(Electrical Box Insert)
Firestop 3500SI	(Intumescent Spray)	Firestop FCW-44	(Firestop Cable Way)
Firestop 3600EX	(Intumescent)	Firestop MP1	(Putty Pad)
Firestop 4100NS	(Non Sag)	Firestop Pillow	(Intumescent Pillow)
Firestop 4100SL	(Self Leveling)	Firestop PPC	(Pipe Collar)
Firestop 4800DW	(Endothermic)	Firestop WS1	(Intumescent Wrap Strip)
Firestop 5100SP	(Sprayable Mastic)	Firestop WS2	(Intumescent Wrap Strip)

CONFORMANCE

TESTED TO STANDARD TEST METHODS:

In the USA:

ASTM E-814	FIRE TESTS OF THROUGH PENETRATIONS FIRE STOPS
ASTM E-84	SURFACE BURNING CHARACTERISTICS OF BUILDING MATERIALS
UL 1479	FIRE TESTS OF THROUGH-PENETRATION FIRESTOPS
UL 2079	TESTS FOR FIRE RESISTANCE OF BUILDING JOINT SYSTEMS

In Canada:

ULC S115-M11 FIRE TESTS OF FIRESTOP SYSTEMS

No Asbestos Or PCBs Are Used Or Contained In These Products

TESTED BY THIRD PARTY AGENCIES:

Underwriters Laboratories, Inc. (UL)
 Intertek Testing Services Inc. – Warnock Hersey (WHI)
 Factory Mutual (FM)
 Omega Point Laboratories (OPL)



OTHER STATE AND LOCAL APPROVALS:

California State Fire Marshal, 4485-1433
 City of New York, NY Report MEA 243-00M
 ICC Evaluation Services – Report ESR-2996

George Rouhana
 Executive Director

Date: March 1, 2018

Recycled
 Recyclable



1.800.810.1788 Technical Support
 1.800.810.1788 Customer Service

www.firestop.com
 email: firestop@firestop.com

Passive Fire Protection Partners
 1412 Derwent Way Delta, BC V3M 6H9